Impact of Long Duration Planned Outages on Paper Mills: A Comparative Study of Three Paper Mills

Harjit Singh Mangat and Harpuneet Singh

Abstract—Considerable attention has been directed throughout the world to assess the economic consequences to electric energy customers due to unreliable power supply. Due to complexity in cost patterns of industrial sector in comparison with residential and commercial sector, a very few studies were conducted in this sector. So, three Craft paper mills of medium scale in Ludhiana (Punjab) were selected as a practical case to conduct a study considering the years 2008 and 2009. Customer survey approach was adopted because the customer is in the best position to assess the effects of interruptions or outages and thus give help to calculate associated costs more accurately. The primary purpose of conducting this survey was to establish monetary losses associated with off-days and peak load imposed by electricity board in 2008 and 2009. The number of weekly off-days and peak load was analyzed accurately through circulars available on the official website of Punjab State electricity Board. The approach called Customer Damage Function (CDF) was used in this study. It includes two terms, one that ascribes a cost to the energy not supplied in Rs/kWh and one that ascribes a cost to the load disconnected. CDF was calculated for three paper mills which portray the costs associated with outages as a function of outage duration.

Index Terms—Unreliable power, outages/interruptions, monetary losses, customer survey, customer damage function.

I. INTRODUCTION

Electric power is an important element in any modern economy. The availability of reliable power supply at reasonable cost is important for economic growth and development of a country. The term reliability is used to indicate the ability of a system to continue to perform its intended function. Power-system reliability refers to availability of electric energy to all its connected customers as and when needed in a desired manner. In modern society, the pattern of social and working habits made mankind wholly dependent on electricity. Moreover, the society as a whole expects the electric supply to be continuously available. Any interruption in supply of electricity causes not only inconvenience, but also certain tangible impacts. Reliability and consistency of electricity supply is critical to many industrial and service activities. For continuous process industries, an unreliable power supply can result in very substantial costs to the operation that includes loss in production, idle labor costs, extra restart costs, delays in

Manuscript received March 9, 2013; revised April 27, 2013.

Harjit Singh Mangat is with the Baba Banda Singh Bahadur Engineering College, Farehgarh Sahib, Punjab, India in Mechanical Engineering Department (e-mail: mangat84@gmail.com).

Harpuneet Singh is with Guru Nanak Dev Engineering College, Gill Park, Ludhiana, Punjab, India in Production Engineering Department (e-mail: harpuneet_gndec@rediffmail.com)

delivery, reduced customer satisfaction and loss of market share. Today's Paper industry, faced by operating and energy cost increase, seeks production optimization and stability but an unreliable power supply is a major barrier to achieving this goal. The critical issue faced by our country is that the demand for electric power is high and growth in supply is constrained by various financial impediments. Many power projects are canceled or postponed due to a lack of resources.

II. METHODOLOGY

The CIGRE TF 38.06.01 Report noted that a variety of methods have been utilized to evaluate customer impacts due to interruptions. These methods can be grouped into the three broad categories of indirect analytical evaluations, case studies of blackouts, and customer surveys [1]. Results from both analytical methods and the case studies have indicated that cost assessments should obtain information that is customer specific. Customer-specific costs are the losses that various customers experience due to the unavailability of the functions, products and activities that are dependent upon power supply. The best source of this information is customers themselves. The methodology widely utilized in quantifying the benefit of electric power system reliability (outage/interruptions) is to estimate the customer monetary losses associated with power supply interruptions by collecting data with customer surveys. Customer surveys can be conducted by e-mail, telephone/mobile or using in-person interviews. The activity began by investigating the possibilities of using these techniques and selecting the most viable approach. E-mail surveys were not considered viable because of the fear of validation of data and poor response rates. Customer surveys by telephone are not feasible because of the detailed customer information requirements and the lack of awareness of the concept and practice. It was therefore decided to conduct survey using in-person interviews [2], [3]. Researchers divided the cost incurred by consumers due to electrical interruptions into two categories direct cost and indirect cost. It is not so easy or possible to find out indirect cost of interruptions, but direct cost is easier to evaluate with more precision and accuracy [4], [5]. That is way direct cost method is utilized in present study to find out the monetary losses incurred by Paper mills. Direct Cost is the cost which is process based and can be evaluated directly such as material costs, manpower costs, fuel costs, market costs and lost production costs. A useful data that relates to cost and other processes were extracted through conversation with an industrial person. The general data was collected while a conversation with the customer. That data was then extrapolated and interpolated to get the useful observations. These observations were then used to estimate the cost and savings of each individual parameter that was affected during outage of different durations. Indirect costs are not evaluated in the study. Following direct costs are included in the study for carrying out the survey and the direct costs that were evaluated are given below: Loss in production, Cost of Idle Manpower, Cost of running backup generator, Cost of boiler fuel wastage and Cost of Market value.

III. RESULTS AND DISCUSSIONS




Fig.1. Shows the peak load hours per day in each month occurred in 2008 and 2009




Fig. 2. Shows the peak load hours per day in each month occurred in 2009

Weekly off days 2008

■ Weekly off day-24 Hours ■ Weekly off day-36 Hours




Fig. 3. Represents the number of weekly off days per month in 2008

Weekly Off Days 2009 Weekly off day-24 hours Weekly off day-16 Hours Weekly off day-33 hours 9 9 8 9 9 9 5 4 4 5 4 5 9 9 9 Jan Feb Mar Apr May Jun Jul Aug Sep Oct Nov Dec

Fig. 4. Represents the number of weekly off days per month in 2009



Fig. 5. Represents the summarized data regarding off days and peak load



Fig. 6. Represents the summarized data regarding off days and peak load

The information regarding the off-days and peak load was collected from circulars available on P.S.E.B official website for the years 2008 and 2009. A critical analysis of these circulars was done in order to find out the actual number of weekly off days of different durations for both the years under consideration. The on-load current measurements for all the electric motors used in paper mills were taken with the help of clamp on ammeter in order to find out the energy consumed by each machine in kWh. These measurements were needed to calculate the machine savings for particular outage duration. The approach called Customer Damage Function (CDF) was used in this study. It includes two terms, one that ascribes a cost to the energy not supplied in Rs/kWh and one that ascribes a cost to the load disconnected. CDF portrays the costs associated with outages as a function of outage duration.

TABLE I: SHOWS THE ELEMENTS OF COSTS AND SAVINGS AND TOTAL LOSS IS CALCULATED FOR DIFFERENT OUTAGE DURATION.

HARISAR PAPERS LTD. (WEEKLY OFF DAYS)											
		24 HOURS		36 HOURS		33 HOURS		16 HOURS			
LO	SSES	2008	2009	2008 2009		2008	2009	2008	2009		
1	PRODUCTION LOSS	407978.18	412358.31	611402.18	617966.31	560546.17	566564.31	272362.00	275286.30		
2	BOILER FUEL WASTAGE	973.96	973.96	973.96	973.96	973.96	973.96	973.96	973.96		
3	SALARIES PAID TO IDLE STAFF	14145.42	14180.10	21198.54	21250.48	19435.30	19482.88	9443.34	9466.48		
4	DIESAL CONSUMPTION IN GENERATOR	125.24	133.32	125.24 133.32 125.24			25.24 133.32		133.32		
CAY	· VINGS	24 HOURS		36 HOURS 33 HOURS			16 HOURS				
SA	VINGS	2008	2009	2008	2009	2008	2009	2008	2009		
1	NO WEAR AND TEAR OF FELT, WIRE, SCREEN	7821.67	7821.67	11721.67	11721.67	10746.67	10746.67	5221.67	5221.67		
2	RAW MATERIAL NOT USED	305403.55	305403.55	457893.55	457893.55	419771.05	419771.05	203743.55	203743.55		
3	BOILER FUEL NOT USED	62953.12	62953.12	94828.12	94828.12	86859.38	86859.38	41703.13	41703.13		
4	ENERGY SAVINGS	40556.00	45062.50	60806.25	67562.50	55743.75	61937.50	27056.25	30062.50		
5	CHEMICALS NOT USED	3133.48	3133.48	4695.88	4695.88	4305.28	4305.28	2091.88	2091.88		

NET LOSS	3554.98	3271.37	3754.45	3622.40	3654.55	3534.57	3088.00	3037.40
MARKET VALUE OF PAPER	76965.39	72584.69	115341.21	108777.08	105747.22	99729.08	51381.39	48457.09
TOTAL LOSS	80520.37	75856.06	119095.70	112399.50	109401.80	103263.60	54469.39	51494.49

TABLE II: SHOWS THE ELEMENTS OF COSTS AND SAVINGS AND TOTAL LOSS IS CALCULATED FOR DIFFERENT OUTAGE DURATION.

	H.B PAPERS PVT. LTD. (WEEKLY OFF DAYS)												
	ana a	24 HOURS		36 HOURS		33 HOURS		16 HOURS					
LO	SSES	2008	2009	2008	2009	2008	2009	2008	2009				
1	PRODUCTION LOSS	332120.05	336933.38	497420.05	504933.38	456320.05	462933.38	221720.05	224933.38				
2	BOILER FUEL WASTAGE	973.96	973.96	973.96	973.96	973.96	973.96	973.96	973.96				
3	SALARIES PAID TO IDLE STAFF	8216.36	8245.24	12313.16	12356.44	11288.96	11328.64	5485.16	5504.44				
4	DIESAL CONSUMPTION IN GENERATOR	125.24	133.32	125.24	133.32	125.24	133.32	125.24	133.32				
SAT	SAVINGS			36 HOURS		33 HOURS		16 HOURS					
SA	11435	2008	2009	2008	2009	2008	2009	2008	2009				
1	NO WEAR AND TEAR OF FELT, WIRE, SCREEN	4813.33	4813.00	7213.33	7213.33	6613.33	6613.33	3213.33	3213.33				
2	RAW MATERIAL NOT USED	234925.80	234925.80	352225.80	352225.80	322900.80	322900.80	156725.80	156725.80				
3	BOILER FUEL NOT USED	62953.12	62953.12	94828.12	94828.12	86859.37	86859.37	41703.13	41703.13				
4	ENERGY SAVINGS	39063.78	43404.20	58568.58	65076.20	53692.38	59658.20	26060.58	28956.20				
5	CHEMICALS NOT USED	2411.50	2411.50	3613.88	3613.88	3313.28	3313.28	1609.88	1609.88				
NE'	LOSS	-2731.90	-2221.70	-5617.30	-4560.20	-4671.00	-3975.70	-1008.30	-663.20				
MA	RKET VALUE OF PAPER	40913.34	36100.01	61613.34	54100.01	56213.34	49600.01	27313.34	24100.01				
TO	TAL LOSS	38181.44	33878.31	55996.04	49539.81	51542.34	45624.31	26305.04	23436.81				

TABLE III: SHOWS THE ELEMENTS OF COSTS AND SAVINGS AND TOTAL LOSS IS CALCULATED FOR DIFFERENT OUTAGE DURATION.

TABLE III: SHOWS THE ELEMENTS OF COSTS AND SAVINGS AND TOTAL LOSS IS CALCULATED FOR DIFFERENT OUTAGE DURATION.													
	CHAMPION PAPER MILL (WEEKLY OFF DAYS)												
LOS	SSES	24 HOURS		36 HOURS		33 HOURS		16 HOURS					
	~~~	2008	2009	2008	2009	2008	2009	2008	2009				
1	PRODUCTION LOSS	284395.80	288511.20	426199.80	432367.20	390748.00	396403.20	189859.80	192607.20				
2	BOILER FUEL WASTAGE	435.38	435.38	435.38	435.38	435.38	435.38	435.38	435.38				
3	SALARIES PAID TO IDLE STAFF	6570.20	6584.64	9846.20	9867.00	9027.20	9047.04	4386.20	4395.84				
4	DIESAL CONSUMPTION IN GENERATOR	81.53	86.79	81.53	86.79	81.53	86.79	81.53	86.79				
CAT	SAVINGS			36 HOURS 33 HOURS				16 HOURS	3				
SA	/INGS	2008	2009	2008	2009	2008	2009	2008	2009				
1	NO WEAR AND TEAR OF FELT, WIRE, SCREEN	3249.00	3249.00	4869.00	4869.00	4464.00	4464.00	2169.00	2169.00				
2	RAW MATERIAL NOT USED	211433.25	211433.25	317003.25	317003.25	290610.75	290610.75	141053.25	141053.25				
3	BOILER FUEL NOT USED	41475.88	41475.88	62373.45	62373.45	57149.06	57149.06	27544.10	27544.10				
4	ENERGY SAVINGS	37636.20	41818.00	56428.00	62698.00	51730.20	57478.00	25108.20	27898.00				
5	CHEMICALS NOT USED	2166.00	2166.00	3246.00	3246.00	2976.00	2976.00	1446.00	1446.00				
NE'	NET LOSS		-4524.10	-7356.80	-7433.30	-6637.90	-6705.40	-2557.70	-2585.20				
MA	RKET VALUE OF PAPER	51334.20	47218.80	76930.20	70762.80	70531.20	64876.80	34270.20	31522.80				
то	TAL LOSS	46856.80	42694.70	69573.40	63329.50	63893.30	58171.40	31712.50	28937.60				

 $TABLE\ IV: Shows\ the\ Elements\ of\ Costs\ and\ Savings\ and\ Total\ Loss\ is\ Calculated\ for\ Different\ Outage\ Duration.$

	HARISAR PAPERS LTD. (PEAK LOAD)											
1.00	SSES	3 HOURS	3.5 HOURS			12 HOURS						
LOS	55E5	2008	2009	2008	2009	2008	2009					
1	PRODUCTION LOSS	51986.18	52544.31	60462.18	61111.31	204554.18	206750.31					
2	BOILER FUEL WASTAGE	973.96	973.96	973.96	973.96	973.96	973.96					
3	SALARIES PAID TO IDLE STAFF	1802.46	1806.88	2096.34	2101.48	7092.30	7109.68					
4	DIESAL CONSUMPTION IN GENERATOR	125.24	133.32	125.24	133.32	125.24	133.32					
CAX	SAVINGS			3.5 HOURS		12 HOURS						
SAV	INGS	2008	2009	2008	2009	2008	2009					
1	NO WEAR AND TEAR OF FELT, WIRE, SCREEN	996.67	996.67	1159.17	1159.17	3921.67	3921.67					
2	RAW MATERIAL NOT USED	38546.05	38546.05	44899.80	44899.80	152913.55	152913.55					
3	BOILER FUEL NOT USED	7171.875	7171.875	8500.00	8500.00	31078.13	31078.13					
4	ENERGY SAVINGS	5118.75	5687.50	5962.50	6625.00	20306.25	22562.50					
5	CHEMICALS NOT USED	399.28	399.28	464.38	464.38	1571.08	1571.08					
NET	LOSS	2655.22	2657.09	2671.87	2671.72	2955.00	2920.40					
MA	RKET VALUE OF PAPER	9807.21	9249.08	11406.21	10757.08	38589.21	36393.08					
TO	TAL LOSS	12462.43	11906.17	14078.08	13428.80	41544.21	39313.48					

TABLE V: Shows the Elements of Costs and Savings and Total Loss is Calculated for Different Outage Duration.

	H.B PAPERS PVT. LTD. (PEAK LOAD)											
1.0	goro	3 HOURS		3.5 HOURS		12 HOURS						
LO	SSES	2008	2009	2008	2009	2008	2009					
1	PRODUCTION LOSS	42320.05	42933.38	49220.05	49933.38	166520.05	168933.38					
2	BOILER FUEL WASTAGE	973.96	973.96	973.96	973.96	973.96	973.96					
3	SALARIES PAID TO IDLE STAFF	1046.96	1050.64	1217.66	1221.94	4119.56	4134.04					
4	DIESAL CONSUMPTION IN GENERATOR	125.24	133.32	125.24	133.32	125.24	133.32					
CAY	SAVINGS			3.5 HOURS	5 HOURS 12 HOURS							
SA	VINGS	2008	2009	2008	2009	2008	2009					
1	NO WEAR AND TEAR OF FELT, WIRE, SCREEN	613.33	613.33	713.33	713.33	2413.33	2413.33					
2	RAW MATERIAL NOT USED	29650.8	29650.8	34538.33	34538.33	117951.69	117625.8					
3	BOILER FUEL NOT USED	7171.875	7171.875	8500	8500	31078.125	31078.125					
4	ENERGY SAVINGS	4930.38	5478.2	5743.08	6381.2	19558.98	21732.2					
5	CHEMICALS NOT USED	307.28	307.28	357.38	357.38	1209.08	1209.08					
NE'	ΓLOSS	1792.545	1869.815	1684.79	1772.36	-472.4	116.2					
MA	RKET VALUE OF PAPER	5213.335	4600.005	6063.335	5350.005	20513.335	18100.005					
TO	TAL LOSS	7005.88	6469.82	7748.125	7122.365	20040.94	18216.21					

TABLE VI: Shows the Elements of Costs and Savings and Total Loss is Calculated for Different Outage Duration.

	CHAMPION PAPER MILL (PEAK LOAD)											
1.0	SSES	3 HOURS		3.5 HOURS		12 HOURS						
LO	35E3	2008	2009	2008	2009	2008	2009					
1	PRODUCTION LOSS	36238.80	36763.20	42147.30	42757.20	142591.80	144655.20					
2	BOILER FUEL WASTAGE	435.38	435.38	435.38	435.38	435.38	435.38					
3	SALARIES PAID TO IDLE STAFF	837.20	839.04	955.50	957.60	3294.20	3301.44					
4	DIESAL CONSUMPTION IN GENERATOR	81.53	86.79	81.53	86.79	81.53	86.79					
CAY	SAVINGS			3.5 HOURS		•						
SA	1103	2008	2009	2008	2009	2008	2009					
1	NO WEAR AND TEAR OF FELT, WIRE, SCREEN	414.00	414.00	481.50	481.50	1629.00	1629.00					
2	RAW MATERIAL NOT USED	26685.75	26685.75	31084.50	31084.50	105863.25	105863.25					
3	BOILER FUEL NOT USED	4905.14	4905.14	5775.85	5775.85	20578.32	20578.32					
4	ENERGY SAVINGS	4750.20	5278.00	5533.20	6148.00	18844.20	20938.00					
5	CHEMICALS NOT USED	276.00	276.00	321.00	321.00	1086.00	1086.00					
NE'	LOSS	562.28	565.52	424.12	426.12	-1597.40	-1615.30					
MA	RKET VALUE OF PAPER	6541.20	5133.60	7607.70	6997.80	25738.20	23674.80					
TO	TAL LOSS	7103.48	5699.12	8031.82	7423.92	24140.80	22059.50					

 $TABLE\ VII: ANNUAL\ LOSS\ CALCULATED\ FOR\ OUTAGE\ DURATION\ OF\ DIFFERENT\ LENGTH\ FOR\ THREE\ PAPER\ MILLS.$

ANNUAL COST SHEET	HARISAR (COST PER OUTAG	E)	ANNUAL OUT	AGES	ANNUAL COST	
WEEKLY OFF DAYS	2008	2009	2008	2009	2008	2009
16 HOURS	54469.39	51494.49	-	5		257472.45
24 HOURS	80520.31	75856.06	49	75	3945495.2	5689204.5
33 HOURS	109401.8	103263.6	-	1		103263.6
36 HOURS	119095.7	112399.5	8	-	952765.6	
TOTAL			57	81	4898260.8	6049940.6
PEAK LOAD	2008	2009	2008	2009	2008	2009
3 HOURS	12462.43	11906.17	258	238	3215306.94	2833668.46
3.5 HOURS	14078.08	13428.8	51	-	717982.08	
12 HOURS	41544.21	39313.48	-	46		1808420.1
TOTAL			309	284	3933289	4642088.6
ANNUAL COST SHEET	H.B (COST PER OUTAG	E)	ANNUAL OUT	AGES	ANNUAL COST	
WEEKLY OFF DAYS	2008	2009	2008	2009	2008	2009
16 HOURS	26305.04	23436.81	-	5		117184.05
24 HOURS	38181.44	33878.31	49	75	1870890.6	2540873.3

33 HOURS	51542.34	45624.31	-	1		45624.31
36 HOURS	55996.04	49539.81	8	-	447968.32	
TOTAL			57	81	2318858.9	2703681.6
PEAK LOAD	2008	2009	2008	2009	2008	2009
3 HOURS	7005.88	6469.82	258	238	1807517.04	1539817.16
3.5 HOURS	7748.125	7122.365	51	-	395154.38	
12 HOURS	20040.94	18216.21	-	46		837945.66
TOTAL			309	284	2202671.42	2377762.82
ANNUAL COST SHEET	CHAMPION (COST PER OUTAG	SE)	ANNUAL OUT	NNUAL OUTAGES ANNUAL COST		
WEEKLY OFF DAYS	2008	2009	2008	2009	2008	2009
16 HOURS	31712.5	28937.6	-	5		144688
24 HOURS	46856.8	42694.7	49	75	2295983.2	3202102.5
33 HOURS	63893.3	58171.4	-	1		58171.4
36 HOURS	69573.4	63329.5	8	-	556587.2	
TOTAL			57	81	2852570.4	3404961.9
PEAK LOAD	2008	2009	2008	2009	2008	2009
3 HOURS	7103.48	5699.12	258	238	1832697.8	1356390.6
3.5 HOURS	8031.82	7423.92	51	-	409622.82	
12 HOURS	24140.8	22059.5	-	46		1014737
TOTAL			309	284	2242320.7	2371127.6

TABLE VIII: CUSTOMER DAMAGE FUNCTION ASSOCIATED WITH WEEKLY OFF DAYS.

	TABLE VIII: CUSTOMER DAMAGE FUNCTION ASSOCIATED WITH WEEKLY OFF DAYS. HARISAR PAPERS LTDCDF CONNECTED LOAD: 642.5 kW															
H	<u>IARIS</u>	<u>AR PAP</u>	ERS LT	'DCDF	1				CON	NECT	ED LO)AD: 6	42.5 k\	<u>N</u>		
COST SHEET	UAL TIME LOSS IINS)	HARISAR (COST PER OUTAGE) 2008 2009		(COST PER OUTAGE) kWh kWh		kWh Company	kWh (Rs/kWh)		CDF (Rs/kWh) PSEB		Outage cost per kW load disconnected		current cost per (1KW-h) 2008 and	Ratio of cost to current rate of cost per kilowatt (1KW-h=Rs 4.5 in 2008 and Rs 5 in 2009) COMPANY		cost to rate of kilowatt =Rs 4.5 and Rs 5
WEEKLY OFF DAYS	ACTI (IN M	2008	2009			2008	2009	2008	2009	2008	2009	2008	2009	2008	2009	
16 HOURS	962	54469.39	51494.49	6000	6012.5		8.56		8.58		80.15		1.71		1.72	
24 HOURS	1442	80520.31	75856.06	9000	9012.5	8.93	8.42	8.95	8.43	125.32	118.06	1.98	1.68	1.99	1.69	
33 HOURS	1982	109401.8	103263.6	12375	12387.5		8.34		8.34		160.72		1.67		1.67	
36 HOURS	2162	119095.7	112399.5	13500	13512.5	8.81		8.82		185.36		1.96		1.76		
AVERAGE						8.87	8.44	8.88	8.45	155.34	119.64	1.97	1.69	1.88	1.69	
H	[.B PA]	PERS P	VT. LTI). – CDI	7				CO	ONNE	CTED I	LOAD	: 652 kV	W		
COST SHEET	SHEET H.B (COST PER OUTLAGE)		R	kWh PSEB	kWh Company		CDF (Rs/kWh) Company		Vh)	Outage cost per kW load disconnected		current cost per (1KW-h) 2008 and	Ratio of cost to current rate of cost per kilowatt (1KW-h=Rs 4.5 in 2008 and Rs 5 in 2009) COMPANY		cost to rate of kilowatt =Rs 4.5 and Rs 5	
WEEKLY OFF DAYS	ACTUAL 1 (IN MINS)	2008	2009			2008	2009	2008	2009	2008	2009	2008	2009	2008	2009	
16 HOURS	962	26305.04	23436.81	5779.2	5791.24		4.05		4.06		35.95		0.81		0.81	
24 HOURS	1442	38181.44	33878.31	8668.8	8680.84	4.40	3.90	4.40	3.91	58.56	51.96	0.98	0.78	0.98	0.78	
33 HOURS	1982	51542.34	45624.31	11919.6	11931.64		3.82		3.83		69.98		0.76		0.77	
36 HOURS	2162	55996.04	49539.81	13003.32	13015.24	4.30		4.31		85.88		0.96		0.96		
AVERAGE						4.35	3.92	4.35	3.93	72.22	52.63	0.97	0.78	0.97	0.79	
C	HAMI	PION PA	APER M	ILL -C	DF				CO)NNE(CTED	LOAD	: 605 kV	W		
COST SHEET	OUTAGE) kWh kWh		kWh	CDF (Rs/kW Compa		CDF (Rs/kW PSEB		Outage c kW load disconne	ost per	Ratio of current : cost per (1KW-h: 2008 and	cost to rate of kilowatt =Rs 4.5 in	ost to ate of illowatt Rs 4.5 in Rs 5				
WEEKLY OFF DAYS	ACTUAL 1 (IN MINS)	2008	2009			2008	2009	2008	2009	2008	2009	2008	2009	2008	2009	
16 HOURS	962	31712.5	28937.6	5568	5579.6		5.19		5.20		47.83		1.04		1.04	
24 HOURS	1442	46856.8	42694.7	8352	8363.6	5.60	5.10	5.61	5.11	77.45	70.57	1.24	1.02	1.25	1.02	
33 HOURS	1982	63893.3	58171.4	11484	11495.6		5.06		5.07		96.15		1.01		1.01	
36 HOURS	2162	69573.4	63329.5	12528	12539.2	5.55		5.55		115.00		1.23		1.23		
AVERAGE						5.57	5.12	5.58	5.13	96.22	71.52	1.24	1.02	1.24	1.03	

TABLE IX: CUSTOMER DAMAGE FUNCTION ASSOCIATED WITH PEAK LOAD.

HARISAR I	PAPER	MILL-	CDF				CO	ONNE	CTEI	LOA	D: 642	2.5 kW			
COST SHEET	ACTUAL TIME LOSS (IN MINS)	HARISAR PER OUTA		kWh PSEB	PNER 1 (1KW-h-Rs 4.5 ii		(Rs/kWh) CDF		rate of cost vatt =Rs 4.5 in I Rs 5 in	Ratio of current i cost per (1KW-h- in 2008 a in 2009) PSEB	rate of kilowatt =Rs 4.5				
PEAK LOAD	A COL	2008	2009			2008	2009	2008	2009	2008 2009		2008	2009	2008	2009
3 HOURS	182	12462.43	11906.17	1125	1137.5	10.95	10.47	11.08	10.58	19.40	18.53	2.33	2.09	2.22	2.12
3.5 HOURS	212	14078.08	13428.8	1312.5	1325	10.62		10.73		21.91		2.36		2.38	
12 HOURS	722	41544.21	39313.48	4500	4512.5		8.71		8.74		61.19		1.74		1.75
AVERAGE						10.78	9.59	10.90	9.66	20.65	39.86	2.34	1.92	2.30	1.93
H.B PAPER	S PVT	. LTD(CDF					CON	NECT	ED LO	DAD:	652kW	·		
TOSZ TAGE TOSZ TAGE		H.B (COST PER OUTAGE)		kWh PSEB	kWh Company	CDF (Rs/kW Compa	PSER		Outage kW load disconn	1	per kilov (1KW-h: 2008 and	rate of cost vatt =Rs 4.5 in	Ratio of current i cost per (1KW-h- in 2008 a in 2009) PSEB	cate of kilowatt =Rs 4.5	
PEAK LOAD		2008	2009			2008	2009	2008	2009	2008 2009		2008	2009	2008	2009
3 HOURS	182	7005.88	6469.82	1083.6	1095.64	6.39	5.91	6.465	5.97	10.74	9.92	1.42	1.18	1.44	1.19
3.5 HOURS	212	7748.125	7122.365	1264.2	1276.24	6.07		6.13		11.88		1.35		1.36	
12 HOURS	722	20040.94	18216.21	4334.4	4346.44		4.19		4.20		27.94		0.84		0.84
AVERAGE						6.23	5.05	6.30	5.08	11.31	18.93	1.38	1.01	1.40	1.02
CHAMPIO	N PAP	ER MIL	L-CDF	=	•	•		CONN	ECTI	ED LC	AD: 6	05 kW			•
ANNUAL COST SHEET	ACTUAL TIME LOSS (IN MINS)	CHAMPIO PER OUTA	N (COST	kWh PSEB	kWh Company	CDF (Rs/kW Compa	'h)	CDF (Rs/kWh) PSEB		Outage kW load disconn	cost per	Ratio of current r per kilov (1KW-h= 2008 and	cost to rate of cost vatt =Rs 4.5 in	Ratio of current i cost per (1KW-h: in 2008 a in 2009) PSEB	rate of kilowatt =Rs 4.5
PEAK LOAD	A N E	2008	2009			2008	2009	2008	2009	2008	2009	2008	2009	2008	2009
3 HOURS	182	7103.48	5699.12	1044	1055.6	6.73	5.40	6.80	5.46	11.65	9.34	1.50	1.08	1.51	1.09
3.5 HOURS	212	8031.82	7423.92	1218	1229.6	6.53		6.59		13.17		1.45		1.46	
12 HOURS	722	24140.8	22059.5	4176	4187.6		5.27		5.28		36.16		1.05		1.06
AVERAGE						6.63	5.33	6.69	5.37	12.41	22.75	1.47	1.07	1.49	1.07

IV. CONCLUSION

A survey on three paper mills has been performed and the results of the survey in form of customer outage costs and customer damage functions have been derived. The primary purpose of conducting this survey was to establish monetary losses associated with various levels of unreliability. CDF portrays the costs associated with outages as a function of outage duration. It has been observed that customer damage function values were maximum for Harisar Paper Mill followed by H.B Papers Pvt. Ltd and Champion Paper Mill This is the first ever study on Paper mills in Ludhiana using customer survey approach.

ACHKNOWLEDGEMENT

The author would like to thank the Punjab State Electricity Board; Industrial customers of paper mills in Ludhiana for the contribution of concerned data; and the staff at the Department of Mechanical and Production Engineering, Faculty of Mechanical and Production Engineering, Guru Nanak Dev Engineering College, Ludhiana

REFERENCES

- [1] CIGRE Task Force 38.06.01, Final Report, Methods to consider customer interruption costs in power system analysis, 2000.
- [2] G. Wacker and G. Tollefson," Electric power system customer interruption cost assessment," *Reliability engineering & system* safety-London: Elsevier, vol. 46, no. 1, pp. 75-82, 1994.
- [3] K. H. La Cammare and J. H. Eto, "Understanding the cost of power interruptions to U.S. electricity consumers," *Ernest Orlando Lawrence University of California Berkeley*, LBNL 55718, PP. 1-50, 2004.
- [4] M. Munasinghe and A. Sanghvi, "Reliability of electricity supply, outage costs and value of service: an overview," *The Energy Journal*,

International Association for Energy Economics, vol. 9 (Special I), pp. 1-18, 1988.

[5] T. Sun, X. Wang, and X. Ma, "Relationship between the economic cost and the reliability of the electric power supply system in city: A case in Shanghai of China," *Applied Energy*, vol. 86, no. 10, pp. 2262-2267, October 2009.



Harjit Singh Mangat was born in Ludhiana, Punjab, India on April 26 1984. He received his B.Tech (Mechanical Engineering) and M.Tech (Production Engineering) degrees from BBSBEC, Fatehgarh Sahib and GNDEC, Ludhiana in 2006 and 2010 respectively. He has been with BBSBEC, Fatehgarh Sahib as an Assistant Professor, Department of Mechanical

and Industrial Engineering, since July 2012 working mainly with impact of power outages on industrial sector. In 2009-2012, he worked as an Assistant Professor with RIMT-MAEC, Mandi Gobindgarh, Punjab, India.



Harpuneet Singh received the M.Tech degree from Thapar University, Patiala in 2001 and Ph.D. degree in Mechanical engineering from University College of Engineering, Punjabi University, Patiala in 2009. He was born on August 03 1976. He is presently an Assistant Professor with the department of Production Engineering in Guru Nanak Dev Engineering

College, Ludhiana, Punjab. His special fields of interest include reliability and interruption cost assessment, Supply Chain Management, Lean Manufacturing and Industrial and Production Engineering.